


NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS AND APPROVED DETAILS.
2. AIR/VAPOR RETARDER TYPE AND PLACEMENT REQUIREMENTS ARE TO BE DETERMINED BY THE SPECIFIER
3. MASONRY JOINTS SHOULD BE STRUCK FLUSH OR PARGE COATED PRIOR TO THE SOPRASEAL SYSTEM APPLICATION.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066		
		TITLE SOPRASEAL STICK 1100T MASONRY WALL FOUNDATION JUNCTION		
SCALE	N.T.S.	DWN RS	CHK RS	APPROVAL DATE 4/29/14
DRAWING NUMBER				REV
AB1100T-007				0