


NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS AND APPROVED DETAILS.
2. AIR/VAPOR RETARDER TYPE AND PLACEMENT REQUIREMENTS ARE TO BE DETERMINED BY THE SPECIFIER
3. MASONRY JOINTS SHOULD BE STRUCK FLUSH OR PARGE COATED PRIOR TO THE SOPRASEAL SYSTEM APPLICATION.
4. THE USE OF A PRIMER WITH SOPRASEAL STICK VP IS OPTIONAL.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281 (330) 334-0066	
TITLE SOPRASEAL STICK VP MASONRY WALL FLOOR JUNCTION			
SCALE	DWN RS	CHK RS	APPROVAL DATE 4/29/14
DRAWING NUMBER ABVP-008			REV 0