


NOTES:

1. COLPHENE FLAM 180 REINFORCEMENT SHALL BE 6" WIDE AND CENTERED OVER CRACK OR JOINT.
2. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS AND APPROVED DETAILS.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281 (330) 334-0066	
TITLE NON-MOVING JOINTS OR CRACKS UP TO 1/8" WIDE			
SCALE	NONE	DWN TM	CHK JP
DRAWING NUMBER			APPROVAL DATE
ANT06			03/15/12
			REV 0

\*\* USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.