


NOTES:

1. DETAIL TO BE USE IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. MINIMUM 1/4" TO MAXIMUM 1/2" SPACING BETWEEN LENGTHS OF TERMINATION BAR: ADD ADDITIONAL FASTENERS AS NEEDED TO ACHIEVE AND MAINTAIN COMPRESSION OF FLASHING MATERIALS.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066	
TITLE FOUNDATION WALL WITH DRAINAGE SYSTEM			
SCALE	DWN TM	CHK JP	APPROVAL DATE 12/29/09
DRAWING NUMBER BGW-1			REV 0