


NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS, APPLICATION METHODS AND APPROVED DETAILS.
2. IF EXPANSION JOINT/FLASHING MEMBRANE IS TO BE COVERED OR BURIED, SUFFICIENT PROTECTION MUST BE PROVIDED BEFORE INSTALLING OVERBURDEN/TOPPING.
3. MINIMUM 1/4" TO MAXIMUM 1/2" SPACING BETWEEN LENGTHS OF TERMINATION BAR: ADD ADDITIONAL FASTENERS AS NEEDED TO ACHIEVE AND MAINTAIN COMPRESSION OF FLASHING MATERIALS.

		310 QUADRAL DRIVE	
		WADSWORTH, OHIO 44281	
		(330) 334-0066	
TITLE DECK TO WALL EXPANSION JOINT			
SCALE	NONE	DWN TM	CHK JP
DRAWING NUMBER			APPROVAL DATE
HRW-501			12/11/09
			REV 0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.