


NOTES:

1. DETAIL TO BE USED IN CONJUNCTION WITH SOPREMA GENERAL REQUIREMENTS AND APPROVED DETAILS.
2. CONSTRUCT OTHER ROOF COMPONENTS ACCORDING TO PROJECT SPECIFICATIONS AND CURRENT RECOMMENDATIONS FROM FMA, SMACNA AND NRCA.
3. SOPREMA FLASHING ADHESIVE, MASTIC, PRIMER (DEPENDING ON APPLICATION METHOD) REQUIRED WHERE INDICATED. SOPREMA SEALANT OR OWNER SPECIFIED SEALANT IS REQUIRED WHERE SEALANT IS INDICATED
4. THE PIPE DIMENSION DICTATES THE NUMBER OF FASTENERS EQUALLY SPACED AROUND THE PENETRATION, I.E. 4" DIA. => 4 FASTENERS, 8" DIA. =>8 FASTENERS.
5. FLASHING FLANGE SHOULD BE DIAGONAL TO FIELD SEAMS.

		310 QUADRAL DRIVE WADSWORTH, OHIO 44281 (330) 334-0066		
		TITLE UNILAY Membrane Fastening @ Penetrations		
SCALE	NONE	DWN DMT	CHK PR	APPROVAL DATE 5/1/05
DRAWING NUMBER ULPN-002				REV 0

** USAGE OF THIS DRAWING IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAIL. PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.