

SENTINEL UNIVERSAL SEALANT

INSTALL A CONTINUOUS BEAD OF BUTYL SEALANT BELOW TOP EDGE OF PVC PIPE FLASHING AND INSTALL PIPE CLAMP AS SHOWN

PVC PIPE FLASHING

HEAT PIPE FLASHING PRIOR TO INSTALLING TO FORM A 1/2" BEND ONTO THE FLASHING MEMBRANE AS SHOWN, HEAT WELD TO FLASHING MEMBRANE

RIB PROFILE

EXTEND FLASHING FLASHING MEMBRANE A MINIMUM OF 3" BEYOND FASTENER PLATES TO ACCOMMODATE A MINIMUM 1.5" HEAT WELDED SEAM TO FIELD MEMBRANE

WRAP PVC PIPE FLASHING AROUND PENETRATION AND HEAT WELD A MINIMUM 1" SEAM AT VERTICAL LAP

HEAT FLASHING MEMBRANE PRIOR TO INSTALLING TO FORM A MINIMUM 1/2" BEND UP THE VERTICAL SURFACE OF THE PENETRATION (PIPE FLASHING CUT AWAY FOR CLARITY)

FLASHING MEMBRANE

TERMINATE FIELD MEMBRANE BY SECURING PERIMETER WITH FASTENERS SPACED A MAXIMUM OF 12" FROM PART PENETRATION AND SPACED A MAXIMUM OF 24" SEAM

SENTINEL FLEECEBACK MEMBRANE, ADHERED WITH DUOTACK SPF "SPATTERN PATTERN"

BASE SHEET/ANCHOR SHEET

DECK

INSULATION

INSULATION

INSULATION

THERMAL BARRIER

SBS FIELD BASE PLY

COVERBOARD


BASE SHEET/ANCHOR SHEET

VAPOR RETARDER/AIR BARRIER

NOTES:

1. SOPREMA DETAIL DRAWINGS: REFER TO SOPREMA AND OTHER RELATED PUBLISHED DOCUMENTATION, PRODUCT DATA SHEETS (PDS) AND SAFETY DATA SHEETS (SDS) FOR ADDITIONAL INFORMATION. ALL DETAIL DRAWINGS AND RELATED INSTALLATION GUIDELINES ARE PROVIDED BY SOPREMA FOR THE SOLE PURPOSE OF ISSUING A SOPREMA WARRANTY. ACCORDINGLY, THE DETAIL DRAWINGS ARE NOT OFFERED, AND SHOULD NOT BE CONSIDERED, AS A SUBSTITUTE FOR PROFESSIONAL DESIGN SERVICES.
2. HOT WORK: THE CONTRACTOR IS RESPONSIBLE FOR DETERMINING APPROPRIATE CONDITIONS TO UTILIZE HEAT-WELDING EQUIPMENT. REFER TO NRCA CERTA RECOMMENDATIONS, LOCAL CODES AND BUILDING OWNER'S REQUIREMENTS FOR HOT WORK OPERATIONS.
3. PRIMER: WHERE NOT SHOWN OR INDICATED ON DETAIL DRAWINGS, REFER TO MATERIAL PRODUCT DATA SHEETS FOR PRIMER APPLICATION REQUIREMENTS.
4. PIPE FLASHING MUST EXTEND VERTICALLY A MINIMUM OF 8" FROM ROOF SURFACE.

1. SOPREMA DETAIL DRAWINGS: REFER TO SOPREMA AND OTHER RELATED PUBLISHED DOCUMENTATION, PRODUCT DATA SHEETS (PDS) AND SAFETY DATA SHEETS (SDS) FOR ADDITIONAL INFORMATION. ALL DETAIL DRAWINGS AND RELATED INSTALLATION GUIDELINES ARE PROVIDED BY SOPREMA FOR THE SOLE PURPOSE OF ISSUING A SOPREMA WARRANTY. ACCORDINGLY, THE DETAIL DRAWINGS ARE NOT OFFERED, AND SHOULD NOT BE CONSIDERED, AS A SUBSTITUTE FOR PROFESSIONAL DESIGN SERVICES.
2. HOT WORK: THE CONTRACTOR IS RESPONSIBLE FOR DETERMINING APPROPRIATE CONDITIONS TO UTILIZE HEAT-WELDING EQUIPMENT. REFER TO NRCA CERTA RECOMMENDATIONS, LOCAL CODES AND BUILDING OWNER'S REQUIREMENTS FOR HOT WORK OPERATIONS.
3. PRIMER: WHERE NOT SHOWN OR INDICATED ON DETAIL DRAWINGS, REFER TO MATERIAL PRODUCT DATA SHEETS FOR PRIMER APPLICATION REQUIREMENTS.
4. PIPE FLASHING MUST EXTEND VERTICALLY A MINIMUM OF 8" FROM ROOF SURFACE.



PVC/SBS HYBRID MEMBRANE, INSULATED, PIPE PENETRATION

US.RPVC.06.11

USAGE OF THIS DETAIL IS GOVERNED BY THE TERMS OF SERVICE FOR SOPREMA DETAILS.
PLEASE CONSULT THESE TERMS OF SERVICE PRIOR TO UTILIZING THIS DRAWING.